



# Load-based Testing of HVAC Systems

Charlie Stephens

Senior Energy Codes & Standards Engineer




# CSA EXP-07: Energy Performance of Split-System and Single-package Air Conditioners and Heat Pumps




# Why is this important?

## DHP




Actual test result				210/240 values (approx)			
Tod	Output	Watts	COP	Tod	Output	Watts	COP
-17	9435	1827	1.5	-17	2347	733	0.9
-5	12287	1884	1.9	-5	4907	785	1.8
5	15030	2160	2.0	5	7040	828	2.5
17	15972	2128	2.2	17	9600	880	3.2
34	9033	1212	2.2	34	13227	954	4.1
47	4021	330	3.6	47	16000	1010	4.6
54	2307	211	3.2	54	17493	1040	4.9

## Projected Usage in kWh vs Previous Period




## Ducted Minisplit, Minute by Minute View for Today



Click and drag in the plot area to zoom in.

# Why is this important?

DHP



210/240 values (approx)

Tod	Output	Watts	COP
-17	2347	733	0.9
-5	4907	785	1.8
5	7040	828	2.5
17	9600	880	3.2
34	13227	954	4.1
47	16000	1010	4.6
54	17493	1040	4.9


Wh Cost



Overlay Sensor Data

View History Details


Yesterday's Master Bedroom Yesterday's Office  
Usage Bedroom #3 Master Bedroom  
Outdoor Temperature Outdoor Temperature



Click and drag in the plot area to zoom in.

# Why is this important?

## DHP



Bedroom #3 Master Bedroom Office Bedroom #2 Master Bath

72°F 73°F 71°F 72°F 72°F


## Projected Usage in kWh vs Previous Period

kWh Cost

This Month To date: 68 kWh 68 kWh

Last Month To same day: 57 kWh 90 kWh

## Ducted Minisplit, Minute by Minute View for Today






# Why is this important?

DHP




Actual test result			
Tod	Output	Watts	COP
-17	9435	1827	1.5
-5	12287	1884	1.9
5	15030	2160	2.0
17	15972	2128	2.2

210/240 values (approx)			
Tod	Output	Watts	COP
-17	2347	733	0.9
-5	4907	785	1.8
5	7040	828	2.5
17	9600	880	3.2
34	13227	954	4.1
47	16000	1010	4.6
54	17493	1040	4.9



20.5  
17.1  
13.6  
10.2  
6.8  
Average EER




# Why is this important?

DHP


Day Week

Yesterday's




Actual test result			
Tod	Output	Watts	COP
-17	9435	1827	1.5
-5	12287	1884	1.9
5	15030	2160	2.0
17	15972	2128	2.2
34	9033	1212	2.2
47	4021	330	3.6
54	2307	211	3.2

210/240 values (approx)			
Tod	Output	Watts	COP
-17	2347	733	0.9
-5	4907	785	1.8
5	7040	828	2.5
17	9600	880	3.2
34	13227	954	4.1
47	16000	1010	4.6
54	17493	1040	4.9



Ducted Minisplit, Minute by Minute View for Today




Click and drag in the plot area to zoom in.

# Harley Residence Heat Pump

## Before and after firmware adjustment

An example of why this matters





# Conventional DOE/AHRI Testing

- Fixed fan and compressor speeds
  - High fan speeds used in test aren't available in normal operation
  - Boosts rated efficiencies
- Doesn't include low-load cycling behavior
- Manufacturer's reps install equipment and monitor testing using proprietary test modes
  - Can't be independently duplicated
- Rating extrapolates performance over a wide range of conditions from two test points (with some adjustments)

# Stakeholder Needs - Accuracy

- Climate-specific ratings
  - Seasonal heating and cooling performance
- Include standby energy
  - Can be significant during shoulder seasons
- DOE ratings (HSPF/SEER) not consistently representative of actual performance
  - Based on **two data points** (with adjustments), **in one climate**
  - **Savings** based on HSPF **not predictive**
  - Meaningful **performance comparisons impossible**
  - Leads to **modeling inaccuracies**

# EXP-07 Development Objectives

- Respond to stakeholder needs:
  - Realistic rating, especially for variable speed systems
  - Seasonal efficiency (heating & cooling) reported for a range of climate zones
  - Detailed data for hourly computer simulation
- Voluntary – *not intended as regulation*
  - Marketplace differentiation of high-performance products
  - Qualified product lists for market support

# Scope

- *Single-stage, multi-stage, and variable speed heat pumps and air conditioners*
- Residential equipment sizes (<65,000 Btu/hr)
- Ducted/ductless (including central ducted)
- Air-to-air, single-zone
  - Multi-zone and air-to-water planned
- Use dynamic, load based testing rather than lab-induced fixed-speed and fixed-condition, tested under the system's own controls, as shipped

# Task Group





- Working group convened by CSA in 2015
  - Project manager: Jovan Cheema
- Comprised of:
  - Canadian utilities (Chair: Gary Hamer – BC Hydro)
  - Natural Resources Canada (NRCan) / CanMetEnergy
  - Northwest Energy Efficiency Alliance (NEEA)
  - Pacific Gas and Electric (PG&E)
  - Electric Power Research Institute (EPRI)
- Tasked to develop a CSA “Express Document”
  - Not full ANSI process, but similar –standards language<sup>13</sup>




# The New Procedures

- Dynamic, load-based testing
- Tested under system's own controls
- Data reported for all test condition intervals
- 4 sets of tests – 2 for cooling, 2 for heating
- Ratings in 8 climate zones
- Bin hours for weighting not the same as DOE's
- Application ratings to be included


# Extensive Lab Work Involved



# Conventional Test Method



# Dynamic Test Method



# Dynamic Load-based Testing

- Indoor room has simulated loads
  - Load is “imposed” by indoor room reconditioning equipment, programmed to mimic load
  - Load varies based on outdoor conditions
  - ***Includes dynamic moisture load for humid/cooling***
  - Equipment under test: on-board thermostat/controls govern system operation as normally installed
- Includes native fan, cycling, defrost and latent removal in a single test procedure
- Tested as shipped



# Data Reported

Test and report data under a wide range of outdoor conditions and building loads:

- Cooling: 5 outdoor room temperatures
  - From 77°F to 113°F (DOE test: 82 & 95)
- Heating: 6 outdoor room temperatures
  - From 54°F to -10°F (DOE test: 17 & 47)
- Report consistent performance data
  - Can be used in hourly building simulations or design

# Test Conditions


## Cooling

	Humid Test Conditions			Dry Test Conditions		
	Outdoor Dry-Bulb Temperature, °F	Indoor Dry-Bulb Temperature <sup>2</sup> , °F	Indoor Wet-Bulb Temperature <sup>3</sup> , °F	Outdoor Dry-Bulb Temperature, °F	Indoor Dry-Bulb Temperature <sup>2</sup> , °F	Indoor Wet-Bulb Temperature <sup>3</sup> , °F
CA <sup>1</sup>	N/A	74	63	113	79	56 (maximum)
CB	104			104		
CC	95			95		
CD	86			86		
CE	77			77		

## Heating


	Standard Outdoor Conditions		Marine Outdoor Conditions		Indoor Conditions	
	Dry-Bulb Temperature, °F	Wet-Bulb Temperature, °F	Dry-Bulb Temperature, °F	Wet-Bulb Temperature, °F	Dry-Bulb Temperature, °F <sup>3</sup>	Wet-Bulb Temperature, °F <sup>4</sup>
HA <sup>1</sup>	-10	-11.4			70	60 (maximum)
HB <sup>1</sup>	5	4				
HC	17	14.5	17	15.5		
HD	34	31	34	32		
HE	47	41	47	45		
HF	54	45	54	49		
HL <sup>1,2</sup>	TOL	TOL-1	TOL	TOL-1		

# Typical Cooling Test Profile



# Performance Data Comparison

- Test COPs match manufacturer engineering data fairly well
- AHRI shown for illustration purposes (From published values at 17/47; not including defrost,  $C_d$ )




# Climate-based Ratings

- 8 North American climate zones
- Based on (simplified) Building America zones
  - Using a grouping analysis by Ecotope
- Test results used to create bin model for annual performance for each climate
  - Seasonal COPs for heating /cooling in each climate
- With and without standby, crankcase, pan heater



# Proposed Climate Zones




# Two Sets of Heating & Cooling Tests


Heating	Cooling
Standard	Dry
Marine	Humid

Rating Climate	Heating	Cooling
Sub-Arctic	Standard	N / A
Very Cold	Standard	Humid
Cold / Dry	Standard	Dry
Cold / Humid	Standard	Humid
Marine	Marine	Dry
Mixed	Standard	Humid
Hot / Humid	Standard	Humid
Hot / Dry	Standard	Dry


# AHRI / DOE Bin Hours (Table 17, p.99)



# EXP-07 Heating Bin Hours



# EXP-07 Cooling Bin Hours - 6 Climates





# Application Ratings

- Use the same set of lab test data as standardized ratings
- Customizable to specific building types and climates
  - In a way that is consistent with standard ratings
- Includes guidance for realistic use of auxiliary heating (e.g., boiler or electric resistance)

# Progress / Next Steps

Lab testing so far:

- PG&E
- Purdue
- NRCan/ CanMetEnergy
  - NGTC
  - UL Plano
- EPRI
- SCE starting
- Many partial; details have varied over time
- Some focused on answering research questions (e.g., simulated loads, repeatability)

# Time Line

- Public comments closed December 2017
- Lab testing will continue
  - Several key issues resolved since last winter
  - Controller apparatus & set-up - Purdue to finish summer 2018
- Stable version by fall 2018, for more lab testing and technical feedback
- Publish in late 2018 or early 2019
- Work starting on air-to-water, and multi-split (residential “VRF”) system types

# Interested Parties

- Canadian Utilities
- Natural Resources Canada
- Some NE Utilities / State agencies / NEEP
- Northwest Utilities / NEEA
- CA Utilities (PG&E, SCE at least)
- Some cities –decarbonization efforts

# Contacts

- Bruce Harley  
Bruce Harley Energy Consulting  
Stamford, VT  
[bruce@bruceharleyenergy.com](mailto:bruce@bruceharleyenergy.com)  
802-694-1719
- Charlie Stephens  
Northwest Energy Efficiency Alliance  
Portland OR  
[cstephens@neea.org](mailto:cstephens@neea.org)  
503 688-5457
- Gary Hamer (Chair)  
BC Hydro  
Vancouver, BC  
[gary.hamer@bchydro.com](mailto:gary.hamer@bchydro.com)  
604 453-6388